



7.8 F-01



TEST REPORT

PARTY CODE : T/JK/12638
ISSUED TO : TRIVENI NURSING HOME
8 C/C, Gandhi Nagar, Jammu, Jammu & Kashmir

REPORT NO. : US0720000522
REF. NO. : NS
REF. DATE : NS
DT.RECD : 20/07/2022



SAMPLE NAME : EFFLUENT WATER (STP-INLET)

RESULTS OF ANALYSIS Reference : Party's Requirement

DESCRIPTION : One Effluent water sample from Inlet of STP was drawn by us on 19/07/2022

SAMPLING DATE : 19/07/2022

SAMPLE QTY. : 1 LTR.

S.No.	Parameters	Units	Results	Protocols
1.	pH	NA	6.88	IS:3025 (P-11)
2.	Total Suspended Solids	mg/L	113	IS:3025 (P-17)
3.	Chemical Oxygen Demand	mg/L	460	IS:3025 (P-58)
4.	Biochemical Oxygen Demand (for 3 days at 27°C)	mg/L	190	IS:3025 (P-44)
5.	Oil & Grease	mg/L	5.6	IS:3025 (P-39)
6.	Phosphate (as P)	mg/L	2.4	IS:3025 (P-31)
7.	Nitrate (as NO ₃)	mg/L	2.6	IS:3025 (P-34)

Date of performance : 20/07/2022 to 25/07/2022

NA = Not Applicable

SAMPLE DRAWN BY US

Arvind Gupta
Tech. Manager (Env.)

Date of completion : 25/07/2022

--- End of Test Report ---

AUTHORISED SIGNATORY



TEST REPORT

PARTY CODE : T/JK/12638
ISSUED TO : TRIVENI NURSING HOME
8 C/C, Gandhi Nagar, Jammu, Jammu & Kashmir

REPORT NO. : US0720000622
REF. NO. : NS
REF. DATE : NS
DT.RECD : 20/07/2022



SAMPLE NAME : EFFLUENT WATER (STP-OUTLET)

RESULTS OF ANALYSIS

Reference : EP Act Standard

DESCRIPTION : One Effluent water sample from Outlet of STP was drawn by us on 19/07/2022

SAMPLING DATE : 19/07/2022

SAMPLE QTY. : 1 LTR.

S.No.	Parameters	Units	Results	Limit (Max.)	Protocols
1.	pH	NA	7.42	5.5 to 9.0	IS:3025 (P-11)
2.	Total Suspended Solids	mg/L	12	100	IS:3025 (P-17)
3.	Chemical Oxygen Demand	mg/L	52	250	IS:3025 (P-58)
4.	Biochemical Oxygen Demand (for 3 days at 27°C)	mg/L	10	30	IS:3025 (P-44)
5.	Oil & Grease	mg/L	<3	10	IS:3025 (P-39)
6.	Phosphate (as P)	mg/L	0.9	5.0	IS:3025 (P-31)
7.	Nitrate (as NO ₃)	mg/L	1.0	10	IS:3025 (P-34)

Date of performance : 20/07/2022 to 25/07/2022

NA = Not Applicable

SAMPLE DRAWN BY US

Arvind Gupta
Tech. Manager (Env.)
AUTHORISED SIGNATORY

Date of completion : 25/07/2022

--- End of Test Report ---

admin

Page : 1 of 1